

SOIL RETENTION
SYSTEM (SHOTCRETE
LAGGING OR OTHER)

PLASTIC FILM
EXTENSION

SIDE LAP DETAIL
(REFER TO SCS-001)

MECHANICAL
FASTENING
(ABOVE PREPRUFE
DETAIL TAPE)

PREPRUFE HYDROPHILIC
SEALANT (UNDER
GEOTEXTILE EXTENSION)

PREPRUFE® 300 MEMBRANE
BASE OF WALL
(REFER TO SCS-011-A & B
AND SCS-018-A & B)

PREPRUFE® SCS
MEMBRANE

VERTICAL TO HORIZONTAL
LAP (REFER TO SCS-012)

PREPRUFE DETAIL TAPE
(CONTINUOUS STRIP AT TOP
OF PREPRUFE 300 AND
ANOTHER CONTINUOUS
STRIP 6-12 in, 150- 300 mm
FROM TOP OF SLAB)

PREPRUFE DETAIL TAPE
MIN 6 in, 150 mm LONG
(A.K.A. BRIDGE
TAPE, TO SEAL VERTICAL
STRIP TO HORIZONTAL
STRIP)

CONCRETE SLAB

NOTES:

- A) INJECTION PORT ASSEMBLY NOT SHOWN FOR CLARITY
- B) HYDRODUCT® OR APPROVED FACING MATERIAL NOT SHOWN ON SOIL RETENTION SYSTEM FOR CLARITY
- C) IF HYDRODUCT IS USED AS PART OF THE DRAINAGE SYSTEM, 6 MIL, 1.5 mm POLY IS REQUIRED BETWEEN THE HYDRODUCT AND THE PREPRUFE SCS MEMBRANE
- D) SEE DETAILS SCS-011-A & B AND SCS-018-A & B FOR SECTION VIEWS AND FURTHER DETAILING INSTRUCTIONS AT BASE OF WALL



BASE OF WALL - ELEVATION DETAIL
PREPRUFE® SCS
WATERPROOFING SYSTEM FOR SHOTCRETE

DRAWING: SCS 009

SCALE: Not to scale

EFFECTIVE DATE: 08/01/2016

SUPERCEDES: SCS 024