

BXUV.X794 Pipe Columns GCP APPLIED TECHNOLOGIES INC — Types Z-106, Z-106/G, Z-106/HY							
Nominal Size	Wall Thickness	A/P	1 hr	1.5 hr	2 hr	3 hr	4 hr
	Other	0.180	1 1/16	1 11/16	2 5/16	3 9/16	NA
	Other	0.190	1	1 9/16	2 3/16	3 3/8	NA
	Other	0.200	15/16	1 1/2	2 1/16	3 3/16	NA
	Other	0.210	7/8	1 7/16	1 15/16	3 1/16	NA
	Other	0.220	7/8	1 3/8	1 7/8	2 7/8	NA
	Other	0.230	13/16	1 5/16	1 13/16	2 3/4	3 3/4
	Other	0.240	13/16	1 1/4	1 3/4	2 11/16	3 5/8
	Other	0.250	3/4	1 3/16	1 11/16	2 9/16	3 7/16
	Other	0.260	3/4	1 3/16	1 5/8	2 7/16	3 5/16
	Other	0.270	11/16	1 1/8	1 9/16	2 3/8	3 3/16
	Other	0.280	11/16	1 1/16	1 1/2	2 5/16	3 1/8
	Other	0.290	5/8	1 1/16	1 7/16	2 3/16	3
	Other	0.300	5/8	1	1 3/8	2 1/8	2 7/8
	Other	0.400	1/2	3/4	1 1/16	1 5/8	2 3/16
	Other	0.500	3/8	5/8	7/8	1 5/16	1 3/4
	Other	0.600	5/16	1/2	11/16	1 1/16	1 7/16
	Other	0.700	5/16	7/16	5/8	15/16	1 1/4
	Other	0.800	1/4	3/8	9/16	13/16	1 1/8
	Other	0.900	1/4	3/8	1/2	3/4	1
	Other	1.000	1/4	5/16	7/16	11/16	7/8
	Other	1.100	1/4	5/16	3/8	5/8	13/16
	Other	1.200	1/4	1/4	3/8	9/16	3/4
	Other	1.300	1/4	1/4	3/8	1/2	11/16
	Other	1.400	1/4	1/4	5/16	1/2	5/8
	Other	1.500	1/4	1/4	5/16	7/16	5/8
	Other	1.600	1/4	1/4	5/16	7/16	9/16
	Other	1.700	1/4	1/4	1/4	3/8	9/16
	Other	1.800	1/4	1/4	1/4	3/8	1/2
	Other	1.900	1/4	1/4	1/4	3/8	1/2
	Other	2.000	1/4	1/4	1/4	3/8	7/16

The information contained in these tables are provided for the convenience of our Monokote customers and while we have taken care to be as accurate as possible and update as listings are modified, GCP will not be held responsible for errors or inaccuracies. In case of discrepancy, values from the applicable design listings and rules associated with adjustment of thickness shall govern.

This table is intended to be used in conjunction with the specified UL Design BXUV.X794. All required components specified in that UL Design shall remain a required component to achieve the hourly ratings. Only the version of UL Design BXUV.X794 as shown on UL.com is considered current.